

# Suad Garments Industries Ltd

Plot # 137-146, Adamjee E P Z, Siddhirganj, Narayanganj, Postal Code: 1431

(23.674345, 90.526076)



21 March 2015



# Observations

**Structure appears susceptible to seismic  
pounding at expansion joint**

**Observations**



Foundation detail

Adjacent columns

Adjacent slab edges

Expansion joint

Separation at expansion joint does not appear sufficient to avoid seismic pounding.

# Observations

Item No.	Observation	Recommended Action Plan	Recommended Timeline
1	Structure appears susceptible to seismic pounding at expansion joint	Structural Engineer to consider robustness against pounding and consider whether it is possible to improve robustness.	6-months