

Powertex Fashions Ltd

Unit 1 DR. A. Latif-Ayesha Tower, Kamarjuri. National University Gazipur

(23.954822N, 90.372626E)


28th February 2015



Observations

Full extent of cantilevers not shown on Permit drawing

Observations



Typical column layout plan



Full extent of cantilevers not shown on Permit drawing

Observations

Priority Actions

Problems Observed

ITEM 1: Full extent of cantilevers not shown on Permit drawing

.

Item No.	Observation	Recommended Action Plan	Recommended Timeline
1	Full extent of cantilevers not shown on Permit drawing	Factory Engineer to confirm design for columns supporting cantilevered slabs.	6-months
2	Full extent of cantilevers not shown on Permit drawing	Factory Engineer to prepare floor loading plans for building as-constructed.	6-months