

FIRE SAFETY INSPECTION REPORT

SAAD SAAN APPARELS LTD.

ACCORD ID: 12398

JAMIRDIA, VALUKA, MYMENSINGH, BANGLADESH.

OTHER FACTORIES: NONE



ACC RD
on Fire and Building Safety in Bangladesh

November 18, 2015

SUMMARY


Saad Saan Apparels Ltd. was surveyed for fire safety on 11/18/2015 by Jensen Hughes. This summary identifies the major deficiencies that were identified during the inspection.

The purpose of this survey was to identify significant fire safety issues and to provide recommendations for remediation based on applicable standards specified by the Accord. The scope of this initial fire safety inspection was limited to the review and identification of major fire safety issues. The inspection did not include identification of minor deficiencies, which will be further addressed as part of follow-up inspections.

Table 1 summarizes the major fire safety issues identified during the inspection. Recommendations have been provided to address each issue.

An implementation schedule shall be developed by the factory to remediate each of the findings. The specific timing of improvements, including any requested extensions due to design / installation constraints, shall be submitted to the Accord for approval.

Table 1. Findings And Recommendations

No.	Category	Finding	Recommendation	Remediation Timeframe
F-1	Fire Rated Construction	The fire pump room is not provided with adequate fire separation.	Provide fire pump room with 2 hr rated fire separation when not sprinklered and 1 hr rated fire separation when provided with automatic sprinklers, in accordance with NFPA 20.	Within 3 months
				
F-2	Fire Rated Construction	Rooms used for combustible storage are not separated form work area by a minimum 1-hr fire-rated construction.	Provide dedicated storage rooms separated by minimum 1-hr fire-rated construction.	Within 3 months




F-3 Egress


Sliding doors are provided at building exits

Replace all gates and sliding doors along the means of egress with side-hinged, swinging egress doors in accordance with ACCORD standard 6.8.1.

Within 1 month



F-4	Fire Protection	The fire alarm system is antiquated, not a listed system and does not provide alarm and notification features consistent with acceptable standards.	Replace the fire alarm system with a new, listed automatic fire alarm system in accordance with NFPA 72 and ACCORD standards.	Design within 4 months, install within 9 months															
					F-5	Fire Protection	Inspection, testing and maintenance for the fire alarm system is not in accordance with NFPA 72.	Inspect, test and maintain the fire alarm system and keep written records on-site, in accordance with NFPA 72 and ACCORD standards.	Within 3 months	F-6	Fire Protection	Inspection, testing and maintenance of portable fire extinguishers is not in accordance with NFPA 10.	Inspect, test and maintain the portable fire extinguishers and keep written records on-site, in accordance with NFPA 10 and ACCORD standards.	Within 3 months	F-7	Fire Protection	Inspection, testing and maintenance of the fire pump system is not in accordance with NFPA 20.	Inspect, test and maintain the fire pump system and keep written records on-site, in accordance with NFPA 20 and ACCORD standards.	Within 3 months
F-5	Fire Protection	Inspection, testing and maintenance for the fire alarm system is not in accordance with NFPA 72.	Inspect, test and maintain the fire alarm system and keep written records on-site, in accordance with NFPA 72 and ACCORD standards.	Within 3 months															
F-6	Fire Protection	Inspection, testing and maintenance of portable fire extinguishers is not in accordance with NFPA 10.	Inspect, test and maintain the portable fire extinguishers and keep written records on-site, in accordance with NFPA 10 and ACCORD standards.	Within 3 months															
F-7	Fire Protection	Inspection, testing and maintenance of the fire pump system is not in accordance with NFPA 20.	Inspect, test and maintain the fire pump system and keep written records on-site, in accordance with NFPA 20 and ACCORD standards.	Within 3 months															

F-8	Fire Protection	Inspection, testing and maintenance of the standpipe system is not in accordance with NFPA 14.	Inspect, test and maintain the standpipe system and keep written records on-site, in accordance with NFPA 14 and ACCORD standards.	Within 3 months
F-9	Fire Protection	The building is equipped with single-station smoke alarms. Smoke alarm activation sounds only a local alarm and does not provide automatic fire alarm notification of occupants.	Remove single-station smoke alarms. Provide automatic smoke detection throughout the building, tied into the fire alarm system, in accordance with NFPA 72 and ACCORD standards.	Within 9 months
				
F-10	Fire Protection	Visible notification was not provided for the building in accordance with NFPA 72.	Provide visible notification for the building in accordance with NFPA 72.	Within 9 months
F-11	Egress Lighting	Inspection, testing and maintenance for the emergency lighting system was not in accordance with ACCORD standards.	Inspect, test and maintain the emergency lighting system in the accordance with ACCORD standards. Keep written records on-site.	Within 3 months

F-12	Egress Lighting	Based on the number and location of emergency lights observed, adequate illumination levels are not anticipated along egress routes.	Test the emergency lighting system on each floor and provide additional emergency fixtures to supply adequate illumination along the means of egress. Provide a minimum illumination of 10 lux at the floor level within exit stairs and along exit discharge paths and a minimum 2.5 lux along exit access aisles.	Within 3 months
------	-----------------	--	---	-----------------