


INITIAL FIRE ASSESSMENT REPORT (FAR)

Factory Name: **Dressmen Apparels Limited**

Address: **Pallirani, Connecting Road (Bhataria), Savar,
Kaliakoir, Shahbajpur, Gazipur Gazipur Dhaka
Bangladesh**

Assessor: **Uttaron Technologies**

Date: **14 Nov 2013**





Introduction to the Report

The following report contains a site profile and summary of non-conformities identified during an onsite assessment commissioned by the Alliance for Bangladesh Worker Safety (Alliance) and conducted by a third-party Qualified Assessment Firm (QAF). The assessment was conducted against the Alliance for Bangladesh Worker Safety Assessment Protocols (APs) and Fire Safety and Structural Integrity Standard, which is harmonized with the factory assessment guidelines developed by Bangladesh University of Engineering and Technology (BUET) for the Bangladesh National Tripartite Plan of Action (NTPA). The goal of the Alliance process is to provide clear and practical technical requirements by which Bangladeshi Ready Made Garment (RMG) Factories producing for Alliance members may be consistently and fairly evaluated for fire, structural, and electrical safety in a non-duplicative manner. Each assessment will prompt action plans that will be used by RMG factories to systematically and sustainably improve safety conditions for garment workers. Beyond tracking and reporting on action steps taken in a transparent manner, the Alliance organization and its members will seek to further support factory improvements through technical assistance, training, implementation support for functional Worker Committees, and in some cases financial assistance and wage support for workers if factories are closed for remediation.

The contents of the report do not constitute a guarantee of compliance with the applicable laws, the Alliance Standard or the absolute or continued safety against fire, electrical and/or structural integrity issues that may lead to injury or loss of life. The report is designed to provide a non-exhaustive summary of risk issues, based on a limited sampling and duration of time onsite by the named QAF. Neither the QAF nor the Alliance can certify or guarantee the quality, outcome, or effectiveness of actions taken in response to the report.

For more information and report feedback please go to: www.bangladeshworkersafety.org.



GENERAL INFORMATION

General Information	
Factory Name:	Dressmen Apparels Limited
Address:	Pallirani, Connecting Road (Bhataria), Savar, Kaliakoir, Shahbajpur, Gazipur Gazipur Dhaka Bangladesh
Country:	Bangladesh
Province:	Dhaka
City:	Gazipur
Zip Code:	1750
Audit Duration:	2 Days
Re-Audit:	Re-Audit After 0 Months
Draft Report Date:	14-Nov-2013
Final Report Date:	Update once final report is complete (after all comments incorporated).
Are all Action Items From Previous Assessment Completed?:	N/A
Buildings in Complex:	3
Is the building(s) owned or rented by the Factory:	Owned
Number of Building Levels (Stories):	Main factory building: 9 stories with occupied roof.
Approximate Building Area (SF):	The area of total factory building is 106,200 sf. (GF: 10,000SF; 1st : 10,000 SF; 2nd: 10,000 SF;3rd:10,000 SF;4th:10,000 SF;5th: 10,000 SF;6th:10,000 SF;7th:10,000 SF;8th:10,000 SF;Roof: 10,000SF.)
Date of Building Construction:	2007
Date of Last Building Renovation/Addition:	No
Ancillary Structures in Complex:	02
Approximate Ancillary Structures Area (SF):	Total area of the ancillary building is 4,600 sf 1. Two story Shed-1: 3,600 sf; 2. One-story Shed-2: 1,000 sf
Number of Occupants:	Total occupancy in the complex is 2,556 (GF: 76, 1st: 71, 2nd: 138, 3rd: 392, 4th: 368, 5th: 397, 6th: 321, 7th:

Factory Name: **Dressmen Apparels Limited**

Address: **Pallirani, Connecting Road (Bhataria), Savar, Kaliakoir, Shahbajpur, Gazipur Gazipur Dhaka Bangladesh**

Assessor: **Uttaron Technologies**

Date: **14 Nov 2013**



ALLIANCE
FOR BANGLADESH WORKER SAFETY

	322, 8th: 117, Roof: 354)
Number of Ancillary Levels (Stories):	Ancillary Shed 1. two story ; Ancillary Shed 2.one story.
Occupancy Type:	G2
Construction Type:	RCC
Height of Highest Occupied Floor Level Above Grade:	90 FT



ASSESSMENT FINDINGS

Fire Protection Construction

Question:	Certificates of Occupancy for each building have been issued and are on file.	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Are certificates of occupancy provided for each building or ancillary structure?	
Question:	Is the fire resistance materials of structural members in good condition and free of damage?	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	BNBC Part 3 Chapter 3	
Question:	Are openings and penetrations through rated walls and/or assemblies protected?	
Priority Level:	High	
Non-Compliance Level:	3	
Description:	Numerous penetrations were found in the barrier walls and through floor slabs used for steam lines and other utilities at almost all floors, which are sealed by using available materials	
Source of Findings:	Photograph: Found numerous penetrations in the barrier walls and through	



	floor slabs used for steam lines	
Suggested Plan of Action:	Install fire-resistive sealant products to provide the required degree of protection for rated walls and assemblies in accordance with the standard.	
Suggested Deadline Date:	16 Oct 2014	
Standard:	Includes doors, windows, ducts, piping, etc. Reference Alliance Standards Part 4 Section 4.6 Opening Protectives and Section 4.7 Penetrations	
Question:	Is each floor separated with a fire-resistive rated construction barrier?	
Priority Level:	High	
Non-Compliance Level:		
Description:	Floors are separated by RC floor slab having 19 mm clear cover have 2.5 hr fire ratings.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference Alliance Standards Part 4 Section 4.5 Separation	
Question:	Are separations between hazards provided with fire-resistive rated construction barriers.	
Priority Level:	Medium	
Non-Compliance Level:	2	
Description:	Other occupancies, hazards, exit enclosures are separated by fire barrier wall (5 inch thick) have 2 hr fire resistance considering plaster and painting and fire wall near lift core and staircase (10 inch thick) have at least a 2 hr resistance rating	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference Alliance Standards Part 4 Section 4.5 Separation	
Question:	Are exit enclosures provided with fire-resistive rated construction barriers?	
Priority Level:	High	



Non-Compliance Level:	3	
Description:	Not found fire door specification and door testing report.	
Source of Findings:	Visual Assessment: Not found fire door specification and door testing report.	
Suggested Plan of Action:	Upgrade and seal the exit enclosures with fire rated barriers and / or assemblies, to meet the requirements of the location and the standard.	
Suggested Deadline Date:	16 Oct 2014	
Standard:	Reference Alliance Standards Part 4 Section 4.5 Separation	
Question:	Are shafts provided with the minimum fire-resistance rating?	
Priority Level:	High	
Non-Compliance Level:		
Description:	The only two (2) shafts are lift shafts. These lift shafts have 10" thick RCC walls having 5 hours fire resistance rating.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference Alliance Standards Part 4 Section 4.5.7.1 through 4.5.7.3	
Question:	Fire dampers installed on air-conditioning and ventilation ducts appear to be in good condition and operational.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference Alliance Standards Part 4 Section 4.6 Opening Protectives and Section 4.7 Penetrations	
Question:	If the building contains a vertical opening known as an atrium, have provisions been made to comply with Alliance Standard 3.7?	



Priority Level:	Medium
Non-Compliance Level:	
Description:	
Source of Findings:	
Suggested Plan of Action:	
Suggested Deadline Date:	
Standard:	Reference Alliance Standards Section 3.7 Atrium

Fire Protection Systems

Question:	Is the building protected by an automatic sprinkler system?
Priority Level:	High
Non-Compliance Level:	3
Description:	No sprinklers system was present during the time of the audit however it is required as the highest occupied floor is above 75 feet from grade.
Source of Findings:	Visual Assessment: No system provided
Suggested Plan of Action:	Consult an experienced fire protection specialist to aid in the site specific design requirements for the installation of a sprinkler system to meet NFPA 13. Ensure this plan is approved by a NFPA certified engineer; then purchase, install, test and commission all necessary components of the system and keep records.
Suggested Deadline Date:	15 Mar 2015
Standard:	Reference Alliance Standards Part 3 Section 3.5.3 Existing Buildings, Part 5 Section 5.3 Automatic Sprinkler Systems and Section 6.13 Travel Distance

Question:	Design criteria of sprinkler system?
Priority Level:	
Non-Compliance Level:	
Description:	
Source of Findings:	
Suggested Plan of Action:	
Suggested Deadline Date:	



Standard:	Provide the criteria used in the design of the sprinkler system.	
Question:	Commodity Class used for the design of the sprinkler system?	
Priority Level:		
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference NFPA 13 Chapter 5	
Question:	Occupancy Classification used for the design of the sprinkler system?	
Priority Level:		
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference NFPA 13 Chapter 5	
Question:	Are inspection, maintenance, and testing procedures of the sprinkler system documented and up to date?	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		



Standard:	Reference NFPA 25 Chapter 5 Sprinkler Systems Table 5.1.1.2	
Question:	Are identification signs for the sprinkler system installed at the required locations?	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference NFPA 13	
Question:	Sprinkler system piping is free of mechanical damage, leakage, and corrosion.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	NFPA 25 Chapter 5 Section 5.2.2 Pipe and Fittings	
Question:	Sprinkler system piping is not subjected to external loads by materials either resting on the pipe or hung from the pipe?	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		



Standard:	Reference NFPA 25 Chapter 5 Section 5.2.2.2	
Question:	Are hangers, bracing, and restraints properly installed and supporting the system piping?	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference NFPA 13 Chapter 9 Hanging, Bracing, and Restraint of System Piping.	
Question:	Sprinklers do not show signs of leakage, are free of corrosion, have not been painted, and are not physically damaged.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference NFPA 25 Chapter 5	
Question:	All valves controlling the automatic sprinkler systems are electrically supervised by a listed fire alarm system control unit.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline		



Date:		
Standard:	Reference Alliance Standard Part 5 Section 5.3.5 Supervision and Alarms.	
Question:	Does the automatic sprinkler system have an approved audible device activated by waterflow equal to the flow of one sprinkler?	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference Alliance Standards Part 5 Section 5.3.5.2 Alarms.	
Question:	Are sprinklers spaced and installed at the required heights in order to provided required coverage and protection?	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference NFPA 13	
Question:	Are storage racks and shelves compliant based on class of commodity storage?	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		



Suggested Deadline Date:		
Standard:	Reference NFPA 13 Chapter 13, 14, 15, 16, or 17	
Question:	Aisles in storage areas are free of storage based on design criteria used for the sprinkler system.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 5 Section 5.3.6.3	
Question:	All storage is maintained with a 460 mm (18 in.) minimum clearance from the top of storage to the sprinkler deflector.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Reference Alliance Standards Part 5 Section 5.3.6.1 Storage Clearance	
Question:	Does the building have a Standpipe System?	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		



Suggested Deadline Date:		
Standard:	Does the building have a standpipe system installed where required. Alliance Standard Part 5 Section 5.4.2	
Question:	Are inspection, maintenance, and testing procedures of the standpipe and hose system documented and up to date? Including inspection and testing of hoses if provided.	
Priority Level:	Low	
Non-Compliance Level:	2	
Description:	Document not found.	
Source of Findings:	Document Review: No records presented, Visual Assessment: N.A	
Suggested Plan of Action:	Establish a Periodic Programmed Maintenance (PPM) plan for the routine inspection, maintenance and periodic testing for the standpipe / hose reel system. This program must incorporate all elements of the installed system and comply with the requirements of NFPA 25.	
Suggested Deadline Date:	16 Jan 2015	
Standard:	Reference NFPA 25 Chapter 6 Standpipe and Hose Systems Table 6.1.1.2	
Question:	Is signage for the standpipe system installed at required locations and on required components?	
Priority Level:	Low	
Non-Compliance Level:		
Description:	No signage was found for the standpipe system	
Source of Findings:	Visual Assessment: None seen during inspection	
Suggested Plan of Action:	Install the required permanent identification signs in compliance with NFPA 14, on all standpipe system equipment and components.	
Suggested Deadline Date:	29 Aug 2014	
Standard:	Reference NFPA 14 Chapter 6	
Question:	Standpipe system piping is free of mechanical damage, leakage, and corrosion?	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		



Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	NFPA 25 Chapter 6 Standpipe and Hose Systems	
Question:	Are fire department connections provided and clearly identified for the Fire Protection Systems?	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 5 Section 5.5.4 Fire Department Connections	
Question:	Does the building have a fire pump?	
Priority Level:	High	
Non-Compliance Level:		
Description:	1 no Fire pump (motor driven), with dedicated generator backup and a direct line from REB for fire pump, and series connection from common generator. Motor power is 75 hp. Also kept provision for standby pump. One Jockey Pump exist but is not in work.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 5 Fire Protection Systems	
Question:	Are inspection, maintenance, and testing procedures of the fire pump documented and up to date?	
Priority Level:	Low	
Non-Compliance Level:	2	



Description:	No record was found for the testing and maintenance of the fire pump	
Source of Findings:	Visual Assessment: No record was found in the factory	
Suggested Plan of Action:	Establish a Periodic Programmed Maintenance (PPM) plan for the routine inspection, maintenance and periodic testing for the fire pump and supporting equipment. This program must incorporate all elements of the installed system and comply with the requirements of NFPA 25.	
Suggested Deadline Date:	16 Jan 2015	
Standard:	Reference NFPA 25 Chapter 8 Fire Pumps	
Question:	Are portable fire extinguishers installed throughout the building at required locations and mounted at the correct height?	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	BNBC Part 4 Section 4.10 and NFPA 10	
Question:	Portable fire extinguishers have been selected based on potential fire class and hazards?	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	NFPA 10 Chapter 5	
Question:	Fire extinguishers are inspected, tested, and maintained as required.	
Priority Level:	Medium	



Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	NFPA 10 Chapter 7	
Question:	Are there any other fire suppression systems installed within the building?	
Priority Level:		
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:		
Question:	Is the fire alarm and detection system monitored by a central station monitoring service or directly connected to the Fire Service and Civil Defense?	
Priority Level:	Medium	
Non-Compliance Level:	3	
Description:	Fire alarm and detection system is not installed	
Source of Findings:	Visual Assessment: No fire alarm panel found	
Suggested Plan of Action:	Install an automatic fire detection alarm system throughout the factory in accordance with NFPA 72. Until that time a central station monitoring service or direct connection to the Fire Service and Civil Defence can be set up; a person needs to be assigned to contact the fire department in the event of fire alarm activation. An annunciator needs to be located in a constantly attended location to alert this person.	
Suggested Deadline Date:	16 Aug 2014	
Standard:	Alliance Standard Part 5 Section 5.7.5 Monitoring	



Question:	Trouble or alarm notifications were not indicated on the fire alarm control panel.	
Priority Level:	High	
Non-Compliance Level:	2	
Description:	Fire alarm control panel not found.	
Source of Findings:	Visual Assessment: Fire alarm control panel not found in the factory	
Suggested Plan of Action:	Install an automatic fire alarm and detection system for the facility. System shall comply with the Alliance Standard and NFPA 72. Consult a qualified fire protection engineer and/or authorized fire alarm company to design and install the system.	
Suggested Deadline Date:	16 Aug 2014	
Standard:	Alliance Standard Part 13 Section 13.10 Maintenance of Fire Protection Equipment	
Question:	Are notification and initiation devices for the fire alarm system installed at required locations based on occupancy type?	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Pull stations at egress points, smoke detectors in air handling equipment, visual and audible devices spaced appropriately based on occupancy type. Reference NFPA 72	
Means of Egress		
Question:	Occupant loads on each level (floor) do not exceed the capacity of the available means of egress.	
Priority Level:	High	
Non-Compliance Level:		
Description:	300 persons are working on each of the 3rd, 4th, 5th, 6th and 7th floors of the factory building which is the maximum number of workers per floor. Two nos.common stairs found in the means of egress	



Source of Findings:	Visual Assessment: N/A	
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.4 Occupant Load	
Question:	Occupied roofs are provided with the minimum number of exits required as a story.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 6 Section 6.6 Number of Means of Egress	
Question:	All occupied roofs are provided with parapets or guards with a minimum height of 1067 mm (42 in.).	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 12 Handrails and Guards	
Question:	Occupant loads are posted for every assembly and production floor in a conspicuous space near the main point of egress.	
Priority Level:	Medium	
Non-Compliance Level:	1	
Description:	Occupant loads are not posted on the floors as required.	



Source of Findings:	Visual Assessment: No signage was seen	
Suggested Plan of Action:	Occupant load signage should be posted for every assembly and production floor, at a conspicuous space near the main exit or exit access doorway for the space.	
Suggested Deadline Date:	16 Aug 2014	
Standard:	Alliance Standards Part 6 Section 6.4.4 Posting of Occupant Load	
Question:	Aisles are provided with the minimum unobstructed clear width of 0.9 m (36 in) based on occupant loads.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Higher occupancy loads will require a greater width to accommodate the increased load. Alliance Standard Part 6 Section 6.5 Egress Width	
Question:	The path of egress along the means of egress is not reduced at any point along the path of travel and is sufficient for the occupant load.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.5 Egress Width and BNBC Table 4.3.2	
Question:	Means of egress have a minimum ceiling height of 2.3 m (7 ft 6 in.) with projections from the ceiling not less than 2.03 m (6 ft 8 in.).	
Priority Level:	Medium	



Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.3.3 Headroom	
Question:	Exit discharge is directly to the exterior of the building, unless the requirements of 6.17.2 are met, at grade or provides direct access to grade. Exit discharge shall not reenter a building.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.17 Exit Discharge. See Section 16.7.2 and 16.7.3 for exceptions.	
Question:	Travel distance to reach an exit does not exceed the maximum distance allowed by Occupancy Type.	
Priority Level:	High	
Non-Compliance Level:		
Description:	The Maximum travel distance found to be 86 ft (26.22m) to reach an exit. As per BNBC Part 4 section 3.15.1 for occupancy G the Maximum travel distance should be 150 ft(45m)	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 13 Travel Distance and BNBC Part 4 Section 3.15.1	



Question:	Exit access corridors serving an occupant load exceeding 30 are separated by walls having a fire-resistance rating of 1 hr.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.3 and Part 4 Section 4.5. Does not apply if an automatic sprinkler system is installed throughout the building.	
Question:	Interior finishes for means of egress meet the rating requirements for Class A, B and C materials.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:	Interior finishes for means of egress meet the rating requirements for Class A, B and C materials.	
Source of Findings:	Visual Assessment: As seen on site	
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.3.2 Interior Finish	
Question:	Exits are limited to Class A and Class B interior materials.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		



Standard:	Alliance Standard Part 6 Section 6.3.2 Interior Finish	
Question:	The number of means of egress from any floor or story is not less than 2 except where a single exit is permitted or where a greater number is required.	
Priority Level:	High	
Non-Compliance Level:		
Description:	There are two(2). common stairs each of which are 60 inch wide.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.6 Number of Means of Egress	
Question:	The number of means of egress from any floor or story is not less than 3 when the occupant load exceeds 500 per story and not less than 4 when the occupant load exceeds 1000 per story.	
Priority Level:	High	
Non-Compliance Level:		
Description:	Occupancy in the complex is 3rd: 392, 4th: 368, 5th: 397, 6th: 321, 7th: 322, 8th: 117, Roof: 354 are working on the factory building which is the maximum number of workers per floor. Two nos. common stairs found in the means of egress.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.6 Number of Means of Egress	
Question:	All paths of egress are provided with compliant means of illumination.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		



Suggested Deadline Date:		
Standard:	Alliance Standards Part 6 Section 6.7 Egress Illumination and Part 10 Section 10.12 Illumination of Exit Signs and Means Of Escape	
Question:	Means of egress are free from impediments, obstructions, and stored materials.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.3.8 Impediments to means of egress and Section 6.3.9 Reliability	
Question:	Emergency power for means of egress illumination is verified at least once per year. If battery operated lights are used, these lights are tested on a monthly basis. Functional testing of battery powered lights is provided for a minimum 90 min once per year.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 10 Section 10.12 Illumination of Exit Signs and Means Of Escape Lighting	
Question:	Doors are not locked in the direction of egress under any conditions. All hasps, locks, slide bolts, and other locking devices have been removed where required.	
Priority Level:	High	
Non-Compliance Level:		



Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 6 Section 6.8 Doors and Gates	
Question:	Doors along the path of egress have a minimum width of 0.8 m (32 in) and have required ratings.	
Priority Level:	High	
Non-Compliance Level:	2	
Description:	There is no fire door in the path of egress. Not a such of report found during visit	
Source of Findings:		
Suggested Plan of Action:	Doors in an existing means of egress shall have a minimum width of 0.8 m (32 in.) and fire rated according to the fire barriers.	
Suggested Deadline Date:	16 Oct 2014	
Standard:	Alliance Standard Part 6 Section 6.5.6 Minimum Widths. Increased occupant loads will require a door width greater than 0.8 m.	
Question:	All doors in a means of egress are of the side-hinged swinging type.	
Priority Level:	High	
Non-Compliance Level:	3	
Description:	Collapsible gates are installed in the means of egress in the factory.	
Source of Findings:	Photograph: Collapsible gates are installed in the means of egress in the factory.	
Suggested Plan of Action:	Replace with side-hinged swinging type door with the necessary fire resistance rating of 1 1/2 hours including door hardware. Position the door so it shall open in the direction of egress without obstructing other paths of egress.	
Suggested Deadline Date:	16 Oct 2014	
Standard:	Alliance Standards Part 6 Section 6.8 Doors and Gates	
Question:	Illuminated exit signs are placed at entrances to exits and along the path of egress anywhere the continuation of egress is not obvious or there is a change	





	in the direction of the path of travel.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:	Lighted exit signs (62) with emergency power supply are provided. Directional lighted exit signs also provided where needed.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.11 Exit Signs	
Question:	Changes in elevation of walking surfaces do not exceed 6.35 mm (1/4 in) unless provided with a beveled slope of 1 in 2 that does not exceed 12.7 mm (1/2 in).	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.3.4 Walking Surfaces	
Question:	Illuminated exit signs are provided with battery backup or emergency power and are continuously illuminated.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		



Standard:	Alliance Standards Part 6 Section 6.11 Exit Signs and Part 10 Section 10.12 Illumination of Exit Signs and Means of Escape	
Question:	Emergency power for exit signs is tested at least once per year. If battery operated, these lights are tested on a monthly basis. Functional testing of battery powered signs is provided for a minimum 90 min once per year.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:	At the means of egress paths 72 emergency lights are found, which have 90 minutes backup that provides illumination of more than 10 lux for all corridors, exit doors stairways and aisles . Inspection and testing are carried out on each month and keep records on maintenance.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 10 Section 10.12 Illumination of Exit Signs and Means Of Escape.	
Question:	Exit signs have appropriate illumination levels and contrasting graphics.	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 10 Section 10.12.1 Exit Signs	
Question:	Walking surfaces along the path of egress are uniformly slip resistant.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:	Walking surfaces and stairway treads are made of 1' x 1' tiles are not glazed. Walking surfaces and stairways are found uniform.	
Source of Findings:		



Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.3.6 Slip Resistance	
Question:	Stairs are constructed of noncombustible materials.	
Priority Level:	Low	
Non-Compliance Level:		
Description:	Side wall of staircases are built with 10 inch thick brick and floor is constructed by 6 inch thick RCC are noncombustible.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.9 Stairs	
Question:	Stairs have a minimum width of 0.9 m (35 in.).	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.5 Egress Width. Applies to existing construction.	
Question:	Stair treads are of nominal uniformity.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		



Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 6 Section 6.9 Stairs. Any tread height exceeding more than 50% of the adjacent tread heights or 75 mm (3 in.), whichever is less, shall be modified to be within this tolerance	
Question:	Landings are provided on both sides of doors used along the path of egress. Doors do not swing out over stairs.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 6 Section 6.8 Doors and Gates	
Question:	Landings are provided with the same width in the direction of egress travel as the stair clear width provided at each level and at intermediate landings. Existing landings that are less than the stair width, shall reduce the overall available capacity of the stair.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.9 Stairs and Section 6.5	
Question:	Handrails are provided on both sides of each stairway. Intermediate handrails are provided when the stair width exceeds 2.2 m (87 in.). Handrails are not mounted lower than 760 mm (30 in.) or higher than 1100 mm (44 in.).	
Priority Level:	Medium	



Non-Compliance Level:	3	
Description:	Handrails are provided on one side of each stairway. The largest stair width is found to be 60 inch.	
Source of Findings:	Visual Assessment: As seen on site	
Suggested Plan of Action:		
Suggested Deadline Date:	16 Oct 2014	
Standard:	Alliance Standard Part 6 Section 6.9 Stairs and 6.12 Handrails and Guards	
Question:	Every door in a stair enclosure serving more than 5 stories is provided with re-entry unless it meets the requirements of Alliance Standards Part 6 Section 6.8.3.1.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:	Locked doors are not found in the means of egress. Every stair gate has re-entry provision.	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 6 Section 6.8 Doors and Gates	
Question:	Exterior exit stairs are separated from the building with the required rating. The rating of the exterior wall shall extend 3.05 m (10 ft) beyond the ends of the stair structure.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.3.1.2. Three stories or less 1-hr rating. Four stories of more 2-hr rating	



Question:	Interior exit stairways and ramps terminate at an exit discharge except where terminating at a rated exit passageway.	
Priority Level:	High	
Non-Compliance Level:		
Description:	No ramps and interior exit found	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.14 Exit Enclosures	
Question:	Stair designation signs are provided at each floor entrance from the stair to the floor in English and Bengali. Signs indicate the name of the stair and the floor level. Signs are posted adjacent to the door.	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 6.9 Stairs	
Question:	Stairwells are not utilized as storage spaces.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		



Standard:	Alliance Standard Part 13 Section 13.9 Safety Inspections	
Question:	Ramps used in a means of egress do not reduce the overall means of egress width. The minimum width shall be 1.1 m (44 in.).	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 6 Section 10 Ramps	
Question:	Ramps do not have a running slope greater than 1 in 8 (12.5 percent) and have handrails on both sides of the ramp.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 6 Section 10 Ramps	
Fire Safety Programs		
Question:	A Fire Safety Director position has been filled.	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline		



Date:		
Standard:	Alliance Standards Part 13 Section 13.1 Fire Safety Director	
Question:	An emergency evacuation plan has been developed and communicated to all employees.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:	Emergency evacuation plan has been explained to all employees	
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 13 Section 13.1 Fire Safety Director	
Question:	Emergency egress maps are posted at the entrance to each exit stair or main point of egress.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 13 Section 13.4 Evacuation Plan	
Question:	Fire Department pre-planning has been completed.	
Priority Level:	Low	
Non-Compliance Level:	1	
Description:	No record found	
Source of Findings:	Visual Assessment: No record found during visit	
Suggested Plan of Action:	Complete fire department pre-planning activities with the local Fire Service and Civil Defense.	
Suggested Deadline	16 Oct 2014	



Date:		
Standard:	Alliance Standards Part 13 Section 13.1 Fire Safety Director	
Question:	Fire Drills are conducted at required intervals based on building use type.	
Priority Level:	Medium	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 13 Section 13.3 Fire Drills	
Question:	Are the required number of people trained and certified in fire fighting, first aid, and rescue training by the appropriate authority.	
Priority Level:	High	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 13 Human Element Programs	
Question:	A written housekeeping policy is established and enforced.	
Priority Level:	Low	
Non-Compliance Level:	3	
Description:	Cleaning of the whole factory is ensured by a total of 37 cleaners. No written policies are present for housekeeping however cleaning is done on a regular basis.	
Source of Findings:	Visual Assessment: No written policies are there for cleaning in the factory	
Suggested Plan of Action:	Produce, establish and enforce a written policy and procedure for housekeeping to ensure scheduled cleaning of all floors, walls, ceilings, air ventilation systems and other building components. Ensure the timely removal	



	of defective, waste and rubbish materials is included. As a general rule the maximum tolerable deposit thickness for loose fluffy lint is 13 mm (½ in.) over a maximum of 46.5 m2 (500 ft2). Limit dense deposits to 6 mm (¼ in.) and oil saturated deposits to 3.2 mm (⅛ in.).	
Suggested Deadline Date:	16 Apr 2015	
Standard:	Alliance Standards Part 13 Section 13.6 Housekeeping	
Question:	A hot-work permit program has been established.	
Priority Level:	Low	
Non-Compliance Level:	2	
Description:	No hot-work permit program has been established. During visit no hot-work operation was occurring in the facility	
Source of Findings:	Document Review: No document related to hot-work permit program has been shown during this assessment., Visual Assessment: N.A.	
Suggested Plan of Action:	Produce and enforce a policy and procedure for the safe execution of all hot work actions in the factory. Provide those required factory workers and contractors with training on the hot work P&P and ensure that all hot work actions follow the P&P.	
Suggested Deadline Date:	16 Jan 2015	
Standard:	Alliance Standards Part 13 Section 13.4 Hot Work Permit and NFPA 51B	
Question:	Storage areas underneath the cutting tables are clear of combustibles.	
Priority Level:	Medium	
Non-Compliance Level:	3	
Description:	Storage areas underneath the cutting tables were not clear of combustible materials.	
Source of Findings:	Visual Assessment: as seen on site	
Suggested Plan of Action:	Produce, establish and enforce a written policy and procedure as part of the main housekeeping policy, to include the underneath zones of the cutting tables; ensuring that they are clear at all times from combustible materials.	
Suggested Deadline Date:	16 Aug 2014	
Standard:	Alliance Standard Part 17 Section 13.7.2 Cutting tables.	
Question:	Training programs are implemented and documented in accordance with the Alliance Safety Training Curriculum.	
Priority Level:	Medium	

Factory Name: **Dressmen Apparels Limited**

Address: **Pallirani, Connecting Road (Bhataria), Savar, Kaliakoir, Shahbajpur, Gazipur Gazipur Dhaka Bangladesh**

Assessor: **Uttaron Technologies**

Date: **14 Nov 2013**



ALLIANCE
FOR BANGLADESH WORKER SAFETY

Non-Compliance Level:	2	
Description:	The factory has not received the Alliance Safety Training Curriculum at the time of the assessment and has not conducted safety training curriculum per Alliance Standards Part 13.	
Source of Findings:	Document Review: No document was shown during inspection., Visual Assessment: N.A.	
Suggested Plan of Action:	Training programs need to be implemented and documented in accordance with the Alliance Safety Training Curriculum.	
Suggested Deadline Date:	16 Aug 2014	
Standard:	Alliance Standards Part 13	
Question:	Smoking is only allowed at designated areas.	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standards Part 13 Section 13.5 Smoking	
Question:	Are all applicable permits up to date including Fire License & Boiler License.	
Priority Level:	Low	
Non-Compliance Level:		
Description:		
Source of Findings:		
Suggested Plan of Action:		
Suggested Deadline Date:		
Standard:	Alliance Standard Part 13 Human Element Programs	
Question:	Are there additional areas of non-compliance to report?	

Factory Name: **Dressmen Apparels Limited**

Address: **Pallirani, Connecting Road (Bhataria), Savar, Kaliakoir, Shahbajpur, Gazipur Gazipur Dhaka Bangladesh**

Assessor: **Uttaron Technologies**

Date: **14 Nov 2013**



ALLIANCE
FOR BANGLADESH WORKER SAFETY

Priority Level:	Medium
Non-Compliance Level:	
Description:	
Source of Findings:	
Suggested Plan of Action:	
Suggested Deadline Date:	
Standard:	Not Applicable